



Nr.	Designation	Ref./DN	QTY	✓
1	ADCATHERM-TDG Deaerator tower		1	
2	Storage vessel		1	
3	ADCATROL make-up water		1	
3.1	Condensate return		1	
4	Vent valve with regulating cone		1	
5	.		1	
6	ADCATROL storage water temp. control		1	
7	ADCA SI steam injection system		1	
8	ADCA S25 humidity separator with trap		1	
9	ADCA FLT steam trap overflow		1	
9.1	Alternative mot. valve overflow		1	
10	Safety valve		1	
11	ADCA RD40 check v. vacuum breaker		1	
12	ADCA VB21 Vacuum breaker		1	
13	Level control		1	
14	Level indicator		1	
15	Vortex breaker		1	
16	Service supply		1	
17	Dosing chemical supply		1	
18	Rtd probe		1	
19	Temperature indicator		1	
20	ADCA MAN 100 pressure indicator		1	
21	ADCA DW sight glass		1	
22	Drain		1	

(TO BEX, see ADBEX.01.2839)

Proj. 07/09/24 F.Saores Des. 07/09/24 Paulo S. Verif.		VALSTEAM ADCA ENGINEERING,SA	Proc. 0.490
Escalas: Tolerancias n/ especificadas Dimensões Desvios > 0 a 5 ±0.2 > 5 a 30 ±0.3 > 30 a 120 ±0.5 > 120 ±0.8 Angulos +/-30° Charfees / Rolos: 0.3			Descrição: THERMAL DEAERATOR TDG-V Without steam dome injection Typical installation
			Des.Nº: ADTDGV.04.2843 Rev: 00 Em: 00/00/00